



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Tim Popp

TTI Environmental Inc.

1253 North Church Street

Moorestown, NJ 08057

Phone: (856) 840-8800

Fax: (856) 840-8815

12/29/2021

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/14/2021. The results are tabulated on the attached data pages for the following client designated project:

21-306/Pamona Pre-School

The reference number for these samples is EMSL Order #012114577. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012114577

CustomerID: TTIE54

CustomerPO: 034013

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 12/14/2021 09:55 AM

Project: 21-306/Pamona Pre-School

Analytical Results

Client Sample Description		BF2 Boiler Room Hallway	Collected:		12/14/2021 6:34:00 AM	Lab ID:		012114577-0001	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		12/27/2021	JW	12/27/2021 17:38	JW
Client Sample Description		WC2 Main Lobby	Collected:		12/14/2021 6:42:00 AM	Lab ID:		012114577-0002	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		3.91	1.00 µg/L		12/27/2021	JW	12/27/2021 17:40	JW
Client Sample Description		BF1 Main Lobby	Collected:		12/14/2021 6:42:00 AM	Lab ID:		012114577-0003	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		12/27/2021	JW	12/27/2021 17:47	JW
Client Sample Description		SK1 Kitchen	Collected:		12/14/2021 6:35:00 AM	Lab ID:		012114577-0004	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		3.82	1.00 µg/L		12/27/2021	JW	12/27/2021 17:49	JW
Client Sample Description		BF3 Back Hallway	Collected:		12/14/2021 6:40:00 AM	Lab ID:		012114577-0005	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		12/27/2021	JW	12/27/2021 17:51	JW

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012114577

CustomerID: TTIE54

CustomerPO: 034013

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 12/14/2021 09:55 AM

Project: 21-306/Pamona Pre-School

Analytical Results

Client Sample Description		WC1 Boiler Room Hallway	Collected:	12/14/2021 6:33:00 AM	Lab ID:	012114577-0006	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	ND	1.00 µg/L	12/27/2021	JW	12/27/2021 17:54	JW
Client Sample Description		WC3 Back Hallway	Collected:	12/14/2021 6:38:00 AM	Lab ID:	012114577-0007	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	ND	1.00 µg/L	12/27/2021	JW	12/27/2021 17:56	JW
Client Sample Description		WC4 Main Lobby	Collected:	12/14/2021 6:41:00 AM	Lab ID:	012114577-0008	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	ND	1.00 µg/L	12/27/2021	JW	12/27/2021 17:58	JW
Client Sample Description		Field Blank Field Blank	Collected:	12/14/2021	Lab ID:	012114577-0009	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	ND	1.00 µg/L	12/27/2021	JW	12/27/2021 18:01	JW

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

